

Certificate No. 164344

TEST FOR THE DETERMINATION OF ACOUSTIC INSULATION TO AIRBORNE NOISE


Test Standards:
UNE-EN 140-3:1995. Measurement of
acoustic insulation in buildings and of
construction elements. Part 3:
Laboratory measurement of acoustic
insulation to airborne noise of
construction elements

Company **GIMÉNEZ GANGA, S.L.U. SHUTTERS**

Section

**THE CASTLE INDUSTRIAL PARK C/ ROMA
Nº4. ALICANTE**

Product	SHUTTER BOX
Model	EURODECOR 185
Dimensions (AnxAI)	1230 mm x 183.7 mm
Material	PVC
Trial Date	27/12/2007



Noise Reduction index, A-weighted, R_A

**Noise Reduction Index
 $R_w (C; C_{tr})$**

39 (-2;-5) dB

33.9 dBA



ENSATEC S.L. –Enero de 2008

**This certification is concomitant with test report reference
No.164344.**

Oscar Ruiz Chicote

Oscar Blanco Navaridas

José Morales Henares