

## Certificate No. 164298

### TEST TO DETERMINE THE COEFFICIENT OF THERMAL TRANSMITTANCE

Test Standards:


UNE-EN 12412-4:2005. Thermal efficiency of windows, doors and shutters. Determination of thermal transmittance by means of the hot box method. Part 4: Roller shutter box

Company **GIMENEZ GANGA, S.L.U. SHUTTERS**  
**THE CASTLE INDUSTRIAL**  
**PARK C/ ROMA Nº4, SAX**  
**(ALICANTE).**

Section

Product	<b>SHUTTER BOX</b>
Model	<b>EURODECOR 185</b>
Dimensions (AnxAI)	<b>1230 mm x 185 mn</b>
Material	<b>PVC</b>

Trial Date **08/02/2008**



**Normalised Thermal Transmittance**  
**(U<sub>sb</sub>)**

**1.7 W/(m<sup>2</sup>K)**



ENSATEC S.L. - February 2008

Oscar Ruiz Chicote  
Rpble. Ext. Enclosures Area

Luis García Viguera  
Construction Department

José Morales Henares  
Director Managing Director

*This certification is concomitant with test report reference No. 164298.*