

**Certificate No. 164348**

***AIR PERMEABILITY AND WATERTIGHTNESS TESTS***

Trial Date 10/01/2008


Test Standards:  
UNE-EN 1026:2000. Windows  
and doors. Air permeability  
UNE-EN 1027:2000. Windows  
and doors. Watertightness.

Company GIMÉNEZ GANGA, S.L.U. SHUTTERS  
AUTOVIA DE LEVANTE, KM 42 SAX. VALENCIA

Section

Product	COMPACT EURODECOR 155
Model	EURODECOR 155
Dimensions (AnxAI)	1230 mm x 155 mm
Box Material	PVC

End Caps Material PVC



QñJtM PCD DJDBUDt-raS  
PVC

**Air permeability**

**CLASS 3**

**Watertightness**

**E3000**

NOTIFIED BODY No. 1668  
for the assessment of conformity with the  
product directive of construction  
89/106/CE

*This certification is concomitant with test report reference No. 164345.*



Classification Standards:  
UNE-EN 12207:2000. Windows  
and doors. Air permeability UNE-  
EN 12208:2000. Windows and  
doors. Watertightness.

ENSATEC/SX. . - February 2008

Oscar Ruiz Chicote Rple. Ext.  
Enclosures Area

Luis García Viguera  
Construction Department  
Director

José Morales Henares  
Managing Director